

Inspection No:	MFD-22--0404
Inspection Date:	05/13/2022
Inspection Time:	0
Inspected By:	Rutherford, Brandon

MARYSVILLE FIRE DIVISION FIRE INSPECTION REPORT



Inspection and Compliance Orders				
Facility:	St. Johns Lutheran Church	Address:	12809 State Route 736 #	
Phone:	937-642-3193			
Fax:		City:	Marysville	
Email:		State:	Ohio	Postal Code: 43040
Primary Contact				
Contact:	Rees, Tonya	Work:		
Email:	Trees@sjsmarysville.org	Cell:		

Inspection Type:	General Inspection
------------------	--------------------

Violation Code	Days to Correct*	Violation	Notes	Location
----------------	------------------	-----------	-------	----------

Inspection Notes:
Exit and egress light stairwell between old and new building. Storage off top shelf in coal room and nothing within 3 ft of the heater. Exit sign by coal room needs repaired to be working and left arrow popped out. Storage height 24 inches below ceiling throughout. Electric panels need clear access to them at least 30 inches. Annual fire door inspection maintenance room needs done and tagged. Exit and egress lights front door mrs aliens room. Exit and egress sign mr. Moran room. Exit and egress light mr. wades front door. Both exit lights speech an counseling. All exit signs with brown outline in new addition please look at to assure they are lit. Fire doors double doors to the tunnel can not be held or blocked open. Maybe get magnet drops with alarm company that can release door in case of a fire alarm. Hood system scheduled to be clean in June have done annually. Ceiling tile above electric service in hot water heater room needs replaced. Church-Exit sign to basement needs repaired. Surge protectors right of the alter need plugged directly into outlets and get rid off the extension cords. Exit sign door into basement metal door. Check all exit and egress lights to ensure compliance. ** Re-inspect is June 13, 2022** A telephone call was received advising that all the fixes were made and they were waiting on surge protectors from amazon for the church which are supposed to arrive soon. Thank you and we will see you next year!

Inspector : Brandon Rutherford	
Owner/Rep. : Tonya Rees	

* Number of days to correct from date inspected.

A variance procedure is available. Please contact the inspector named for further assistance with this or any other matter.